



# 中国国家强制性产品认证证书



证书编号: 2021322309004026

认证委托人名称: 可莱特电子(启东)有限公司  
认证委托人地址: 江苏省南通市启东市启东高新技术产业开发区海燕路 33 号  
生产者名称: 可莱特电子(启东)有限公司  
生产者地址: 江苏省南通市启东市启东高新技术产业开发区海燕路 33 号  
生产企业名称: 可莱特电子(启东)有限公司  
企业地址: 江苏省南通市启东市启东高新技术产业开发区海燕路 33 号  
产品名称: 火灾声光报警器  
系列、规格、型号: SESA 系列  
标准: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。  
产品相关信息详见附件。

发证日期: 2023 年 04 月 14 日

有效期至: 2026 年 05 月 30 日

首次发证日期: 2021 年 05 月 31 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2021322309004026**

**APPLICANT:** QLIGHT ELECTRONICS(QIDONG)CO.,LTD.  
**ADDRESS:** 33,HAIYAN ROAD,QIDONG HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE,QIDONG,JIANGSU PROVINCE  
**MANUFACTURER:** QLIGHT ELECTRONICS(QIDONG)CO.,LTD.  
**ADDRESS:** 33,HAIYAN ROAD,QIDONG HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE,QIDONG,JIANGSU PROVINCE  
**FACTORY:** QLIGHT ELECTRONICS(QIDONG)CO.,LTD.  
**ADDRESS:** 33,HAIYAN ROAD,QIDONG HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE,QIDONG,JIANGSU PROVINCE  
**PRODUCT:** Fire Warning Light & Electric Horn Combinations  
**SERIES,SPECIFICATION,MODEL:** SESA Series  
**STANDARDS:** GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.31-2021

**Type of Certification: Type test + Initial inspection + Surveillance inspection**

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

**Valid from:** April 14, 2023

**Valid until:** May 30, 2026

**Date of original certification:** May 31, 2021

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

  
Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

**S 0007189**





# 中国国家强制性产品认证证书



证书编号: 2021322309004026

## 附 件

- 产品名称: 火灾声光警报器
- 型号规格: SESAa-b-c  
a 代表型号, 可为: 无后缀(灯泡反射镜旋转型)、L(LED长亮闪亮型)、LR(LED反射镜旋转型)、S(频闪管爆闪型);  
b 代表音调, 可为: WS(警告音)、WP(特殊警告音)、WM(音乐音)、WA(提示音)、WV(声音信号);  
c 代表电压, 可为: 12(12VDC)、24(24VDC)、120(120VAC)、230(230VAC)。
- 防爆标志: Ex db IIC T6 Gb、Ex tb IIIC T80°C Db
- 电气参数: U=12VDC、24VDC、120VAC 或 230VAC
- 相关报告编号: 2022S17402-010407、2022S17402-008672、2021S17402-005385
- 使用条件:  
1. 特殊(限制)使用条件:  
1) 涉及隔爆接合面的维修须联系产品制造商。  
2) 隔爆接合面用紧固件的性能等级至少为 737N/mm<sup>2</sup>。  
3) 产品使用环境温度: -40°C ~ +60°C。  
2. 外壳防护等级 IP66。

批 准:



## 上海仪器仪表自控系统检验测试所有限公司